



A = Comms: 160mm, Outer Diameter HDPE ESB Approved Duct SDR=17.6
 B = Power: 160mm, Outer Diameter HDPE ESB Approved Duct, SDR=17.6
 C = ECC: 160m, Outer Diameter HDPE ESB Approved Duct, SDR=17.6

110kV Ducting in IPP Substation

SCALE 1:10

Note:

- Dimensions are in millimeters, unless noted otherwise.
- Drawings are not to be scaled use figured dimensions only.
- A minimum separation distance of 300mm from standard services will be maintained at all times.



Head Office
 Beenreigh,
 Abbeydorney,
 Tralee, Co. Kerry
 Ireland
 Tel: 00353 66 7135710



CLIENT
**Ballynahone Long Duration
 Energy Storage**

PROJECT NUMBER: 05-1040
 SHEET NUMBER: 051040-DR-104

SHEET TITLE
**110kV Ducting in IPP
 Substation - Section**

DRAWING STATUS
 For Planning

ISSUE/REVISION		
I/R	DATE	DESCRIPTION
P2	22.08.24	Issued for Planning
P1	30.05.24	Issued for Planning